



Member of the FM Global Group

Not to be distributed outside of FM Approvals and its affiliates except by Customer

APPROVAL REPORT

Project I.D. No: 3049529
Class: 4471
Product Name: DURS PB 12 – 14 and METALIC CABEÇA LENTILHA PB ¼
– 14 Fasteners for Use in Metal Panel Roof Assemblies in
accordance with FM 4471
Name of Listing Company: Hard Comercio De Fixadores
Address of Listing Company: Rua Humberto Pinheiro Vieira 150 Lote 1B
E Resinas Ltda
Distrito Industrial
Joinville Santa Catarina CEP89219-570
Brazil
Customer ID: 144787-1
Customer website: <http://www.hard.com.br>

Prepared by

Michael P. DeSousa
Engineer, Material

Reviewed by

R. Scott Holmes
Technical Team Manager, Materials

Cynthia E. Frank
AVP, Manager, Materials

3/24/2014

Date of Approval

1 INTRODUCTION

- 1.1 Hard Comercio De Fixadores requested Approval of their DURS PB 12 – 14 and METALIC CABEÇA LENTILHA PB 1/4 – 14 Fasteners to determine if they meet the Approval requirements of the standard listed in Section 1.4.
- 1.2 Test Data was released from other sponsors for the purpose of this Approval. See Project IDs 3047334 and 3047495 for details.
- 1.3 This report may be freely reproduced only in its entirety and without modification.
- 1.4 **Standard**

Title	Number	Issue Date
Approval Standard for Class I Panel Roofs	4471	3/2010

1.5 Listing

The products will be listed in RoofNav, an on-line resource of FM Approvals. Drawings and specifications are on file at FM Approvals.

2 DESCRIPTION

DURS PB 12 – 14 and METALIC CABEÇA LENTILHA PB 1/4 – 14 Fasteners are described as follows:

- 2.1 DURS PB 12 – 14 are Size No. 12 screws Approved in lengths ranging from minimum 25.4 mm (1.0 in.) to maximum 50.8 mm (2.0 in.) long containing 14 threads per 25.4 mm (1 in.) of a coarse-thread series, a 7.85 mm (0.31 in.) hexagon drive head with an EPDM washer and a pilot drilling tip. The threads have a 5.5 mm (0.186 in.) maximum major diameter and 4.6 mm (0.181 in.) minimum minor diameter. The screws are Zinmec coated or Ecoséal Zinmec coated and the screw heads can be painted over the coating in various colors as desired.
- 2.2 METALIC CABEÇA LENTILHA PB 1/4 – 14 screws are Approved in lengths ranging from minimum 25.4 mm (1.0 in.) to maximum 41.3 mm (1-5/8 in.) long containing 14 threads per 25.4 mm (1 in.) of a coarse-thread series, a 12.1 mm (0.476 in.) Torx (30) drive head with no washer. The threads have a 6.3 mm (0.248 in.) maximum major diameter and a 5.3 mm (0.21 in.) diameter pilot drilling tip. The screws are zink plated or ecoséal coated.
- 2.3 All products are as described in RoofNav. Formulations, drawings and specifications are on file at FM Approvals.

3 EXAMINATIONS AND TESTS

- 3.1 All components including those in Sections 2.1 – 2.2, are referenced in Project 3047334 and 3047495 or were produced under the FM Approvals Surveillance Audit program as indicated by FM Approvals labels. All samples were considered to be representative of standard production and were examined and tested as indicated below. Components incorporated into test samples were selected by FM Approvals personnel. Test samples

were prepared by, or under the supervision of, FM Approvals personnel. All data is on file at FM Approvals along with other documents and correspondence applicable to this program.

- 3.2** Several performance requirements and tests required by the Standard have been waived due to previous successful testing. See Table 1 below for details.

Table 1

FM Standard 4471 Performance Requirement	Original Project IDs
Combustibility From Above the Roof Deck	Waived, See 3047334 and 3047495
Combustibility From Below the Roof Deck	Waived ¹
Wind Uplift Resistance Test	Waived, See 3047334 and 3047495
Foot Traffic Resistance Test	Waived, See 3047334 and 3047495
Hail Damage Resistance Test	Waived, See 3047334 and 3047495
¹ All insulations are Approved by the OEM, no new insulations included.	

4 MARKING

- 4.1** The manufacturer shall mark each packaging with the manufacturer's name and product trade name. In addition, packaging must be marked with the Approval Mark of FM Approvals.
- 4.2** Markings denoting Approval by FM Approvals shall be applied by the manufacturer only within and on the premises of manufacturing locations that are under the FM Approvals Surveillance Audit program.
- 4.3** The manufacturer agrees that use of the FM Approvals name or Approval Mark is subject to the conditions and limitations of the Approval by FM Approvals. Such conditions and limitations must be included in all references to Approval by FM Approvals.

5 REMARKS

- 5.1** The securement of the roof system must be enhanced at the building corners and perimeter as outlined in FM Global Property Loss Prevention Data Sheet 1-29.
- 5.2** The roof cover must be installed using a roof perimeter flashing system Approved by FM Approvals. See RoofNav.

6 SURVEILLANCE AUDIT

The manufacturing facility at the following location shall be visited on a routine basis. The facility processes and quality control procedures in place have been determined to be satisfactory to manufacture products identical to that tested and Approved. A Form

797 shall be submitted to FM Approvals for requesting to manufacture products at any additional or alternate manufacturing facilities which are not listed below.

Audit Location

Hard Comercio De Fixadores
Rua Humberto Pinheiro Vieira 150 Lote 1B
E Resinas Ltda
Distrito Industrial
Joinville Santa Catarina CEP89219-570
Brazil

7 MANUFACTURER’S RESPONSIBILITIES

- 7.1 The manufacturer shall notify FM Approvals of any planned change in the Approved products, prior to general sale or distribution, using Form 797, Approved Product Revision Report. No changes of any nature shall be made unless notice of the proposed change has been given and written authorization obtained from FM Approvals.
- 7.2 To ensure compliance with his procedures in the field, the manufacturer shall supply to the installer such necessary instruction or assistance required to produce the desired performance achieved in the tests.
- 7.3 In accordance with the Master Agreement, the manufacturer shall make full and immediate disclosure to FM Approvals of all information concerning any defect in, or potential hazard of, the product or service manufactured or provided by the Customer which is Approved by, or being examined by, FM Approvals. The manufacturer shall make all necessary arrangements for the investigation of complaints / anomalies applicable to this approval and shall keep records of all complaints / anomalies including actions taken.

8 DOCUMENTATION

The following document describes the DURS PB 12 – 14 and METALIC CABEÇA LENTILHA PB 1/4 – 14 Fasteners and is on file at FM Approvals.

Document Title	Issue Date	Description
Surveillance Audit Manual for Hard Comercio De Fixadores	March 2014	Drawings, Raw Materials, Specifications, Quality Control and Production Procedures

9 CONCLUSIONS

- 9.1 Test results from this and previous test programs indicate that the submitted products as evaluated, meet the requirements of FM Approvals Standard listed in section 1.4.

- 9.2 Tests show that the tested roof constructions in and of themselves would not create a need for automatic sprinklers.
- 9.3 Since a duly signed Master Agreement is on file for this customer, Approval is effective as of the date of this report.
- 9.4 Continued Approval will depend upon satisfactory field experience and periodic Facilities and Procedures Audits.

PROJECT DATA RECORD: 3049529

ATTACHMENTS: None

ORIGINAL TEST DATA: See Project Data Records (PDRs) for Project IDs 3047334 and 3047495